



For Listing/Approval Details and Limitations, visit our website at www.anvilstar.com or contact an Anvil®/AnvilStar™ Sales Representative.

FIGURE 7072 CONCENTRIC REDUCER (GROOVE BY GROOVE)

Nominal Size	O.D.-1	O.D.-2	End to End	Approx. Wt. Ea.
In./DN(mm)	In./mm	In./mm	In./mm	Lbs./Kg
2½ x 2 ■ 65 x 50	2.875 73.0	2.375 60.3	2½ 64	1.6 0.7
3 x 2 ■ 80 x 50	3.500 88.9	2.375 60.3	2½ 64	1.4 0.6
3 x 2½ ■ 80 x 65	3.500 88.9	2.875 73.0	2½ 64	1.6 0.7
4 x 2 ■ 100 x 50	4.500 114.3	2.375 60.3	3 76	2.4 1.1
4 x 3 ■ 100 x 80	4.500 114.3	3.500 88.9	3 76	3.2 1.5
5 x 4 ■ 125 x 100	5.563 141.3	4.500 114.3	3½ 89	4.5 2.0
6 x 3 ■ 150 x 80	6.625 168.3	3.500 88.9	4 102	5.4 2.4
6 x 4 ■ 150 x 100	6.625 168.3	4.500 114.3	4 102	5.6 2.5
6 x 5 ■ 150 x 125	6.625 168.3	5.563 141.3	4 102	6.0 2.7
8 x 4 ■ 200 x 100	8.625 219.1	4.500 114.3	5 127	9.0 4.1
8 x 6 ■ 200 x 150	8.625 219.1	6.625 168.3	5 127	15.5 7.0
10 x 6 ■ 250 x 150	10.750 273.1	6.625 168.3	6 152	20.0 9.1
10 x 8 ■ 250 x 200	10.750 273.1	8.625 219.1	6 152	23.9 10.8
12 x 8 ■ 300 x 200	12.750 323.9	8.625 219.1	7 178	29.0 13.2
12 x 10 ■ 300 x 250	12.750 323.9	10.750 273.1	7 178	32.4 14.7

Additional sizes available, see Golvok Catalog or contact an AnvilStar Representative.

■ – Cast fittings, all others are fabricated steel.

Available as a fabricated fitting.

☞ – Available galvanized.

MATERIAL SPECIFICATIONS

CAST FITTINGS:

Ductile Iron conforming to ASTM A-536
Malleable Iron conforming to ASTM A-47

FABRICATED FITTINGS:

1"–10" Carbon Steel, Schedule 40, conforming to ASTM A-53, Grade B
12" and above Carbon Steel, Standard Wall, conforming to ASTM A-53, Grade B

COATINGS:

Rust inhibiting paint Color: ORANGE (standard) or
Hot Dipped Zinc Galvanized conforming to ASTM A-153 (optional)
Other available options: Example: RAL3000 or RAL9000 Series

PROJECT INFORMATION		APPROVAL STAMP	
Project:		<input type="checkbox"/> Approved	
Address:		<input type="checkbox"/> Approved as noted	
Contractor:		<input type="checkbox"/> Not approved	
Engineer:		Remarks:	
Submittal Date:			
Notes 1:			
Notes 2:			