



**BULL MOOSE TUBE COMPANY**

1819 Clarkson Road, Suite 100 • Chesterfield, Missouri 63017  
(636) 537-2600 • [www.bullmoosetube.com](http://www.bullmoosetube.com)

July 29, 2008

Subject: CPVC Compatibility with Quakercool 2871 and Eddy Guard II.

To Whom It May Concern:

Bull Moose Tube Company performed a Chlorinated Polyvinyl Chloride (CPVC) compatibility test with Quakercool 2871 and Eddy Guard II through an Independent Third Party Material Testing and Engineering Laboratory.

The Material Testing and Engineering Laboratory concluded that Quakercool 2871 and Eddy Guard II did not have any detrimental effects on the CPVC Sprinkler Pipe Samples.

Quakercool 2871 is the mill coolant used during production of "Eddy Pipe" Sprinkler Pipe in all Bull Moose Tube Company production facilities and Eddy Guard II is our antimicrobial coating.

Sincerely,  
Mark S. Abernathy  
Manager of Engineered Sales

Cc: file